STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110859
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35353

1. OWNER Palm mortuary
MAILING ADDRESS 1325 N Main Street
Las Vegas, Nevada 89101

ADDRESS AT WELL LOCATION 1325 N Main Street
Las Vegas, Nevada 89101
Subdivision Name: MW-4 County: Clark

2. LOCATION NE ¼ NE ¼ Sec 27 T 20S N/S R 61 E
PERMIT/WAIVER No. NDEP 8-000145 (Issued by Water Resources) 139-27-504-012 (Parcel No.)
Latitude 36.18610 N
Longitude -115.13554 W
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC [ ] Air [X] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Sandy Gravel w/ silt - brown		0	3	3
Sandy Clay - Ltbrn		3	6	3
Caliche - white		6	8	2
Sandy Clay - Ltgn	x	8	12	4
Sandy Clay - rdbrn		12	15	3
Clayey Sand - rdbrn		15	19	4
Fat Clay - gnbrn to rdbrn		19	24	5

RECEIVED
APR 27 2010
LAS VEGAS OFFICE

Date started: 19-Apr, 20 10
Date completed: 19-Apr, 20 10

9. WELL CONSTRUCTION
Depth Drilled 24 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	24	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	Sch 40	PVC	0	9

Perforations:
Type of perforation 2" OD Factory Slotted Sch 40 PVC
Size of perforation .02
From 9 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [ ] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 8 to 24 [ ] Pumped [X] Poured
Type: Number 3 Cemex Sand
Bentonite Chips: [X] Yes [ ] No 1 to 8 [ ] Pumped [X] Poured
Type: 3/8" Hole Plug Bentonite Chips

7. Water Level
Static water level: 11.99 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Terracon Consultants (Contractor)
Address 750 Pilot Road Suite F Las Vegas Nevada 89119 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board*
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2409
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-27-2010

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY