STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110873
Permit No. —
Basin 04B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65185

1. OWNER Mitch Pommerening Jan & Angie
MAILING ADDRESS Spring Creek, NV 89815

ADDRESS AT WELL LOCATION Corner of Beauregard Av & 6th St # 1135 Beauregaurd Ave.
Subdivision Name: Lucky Nugget Ranches County: Elko

2. LOCATION SW ¼ NE ¼ Sec 15 T 32N N/S R 55 E
PERMIT/WAIVER No. 027-010-008
Issued by Water Resources — Parcel No.

Latitude W.115 45.690
Longitude 40 39.563
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
brown clay		2	18	16
boulders & gravel	26	18	32	14
silt stone & gravel	60	32	105	73
silt stone & large gravel	105	105	120	15

GPS NAD-27
40.659383°N
115.761500°W

Date started: 10-Mar, 20 10
Date completed: 20-Mar, 20 10

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation: mill slot
Size of perforation: 3/16x3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 100 [X] Pumped [ ] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 100 to 120 [ ] Pumped [X] Poured
Type: pea gravel
Bentonite Chips: [ ] Yes [ ] No to [ ] Pumped [ ] Poured
Type:

7. Water Level
Static water level: 13 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		4

RECEIVED 2010 APR -9 AM 11:52 STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name David Hersh (Contractor)
Address P.O. Box 281166 (Contractor)
Lamoille, NV 89828
Nevada contractor's license number issued by the *State Contractor's Board* 73955
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1689
Signed (By driller performing actual drilling on site or contractor)
Date 7-Apr-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

PLO-I
MH-F