

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110878
Permit No. 761
Basin 19/2

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 61413

1. OWNER Newmont Mining Corp.
MAILING ADDRESS PO Box 669
Carlin, NV 89822

ADDRESS AT WELL LOCATION North Area 4-2 Tails
Hole # MW-42-16S
Subdivision Name: _____ County: Eureka

2. LOCATION NW 1/4 NW 1/4 Sec 3 T 35N N/S R 50 E
PERMIT/WAIVER No. NV87065
Issued by Water Resources Parcel No. _____

Latitude _____ UTM E 2589089 NAD 27
Longitude _____ N 256700 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|--------------|------|----|-----------|
| Alluvium | | 0 | 80 | 80 |
| <u>NAD-27 GPS</u> | | | | |
| <u>40,945175°N</u> | | | | |
| <u>116.349078°W</u> | | | | |
| RECEIVED 2008 OCT 20 PM 2:35 STATE ENGINEERS OFFICE | | | | |

9. WELL CONSTRUCTION

| | | | | | |
|--------------------------|------------------------|----------------------------|----------------|--------------|------|
| Depth Drilled | 80 | Feet | Depth Cased | 78 | Feet |
| HOLE DIAMETER (BIT SIZE) | | | | | |
| | From | | To | | |
| | 14 3/4 | Inches | 0 | Feet | 19 |
| | 8 3/4 | Inches | 19 | Feet | 80 |
| | | Inches | | Feet | Feet |
| CASING SCHEDULE | | | | | |
| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) | |
| 4 1/2 | | Sch 80 PVC | + 2 | 78 | |

Perforations:

| | |
|---------------------|------------|
| Type of perforation | Slot |
| Size of perforation | 0.02 |
| From 58 | feet to 78 |
| From | feet to |

Annular Seal: Yes No

| | | | |
|---|---------|---------------------------------|--|
| <input checked="" type="checkbox"/> Neat Cement | 0 to 50 | <input type="checkbox"/> Pumped | <input checked="" type="checkbox"/> Poured |
| <input type="checkbox"/> Cement Grout | to | <input type="checkbox"/> Pumped | <input type="checkbox"/> Poured |
| <input type="checkbox"/> Concrete Grout | to | <input type="checkbox"/> Pumped | <input type="checkbox"/> Poured |
| <input type="checkbox"/> ≥30% Bentonite Grout | to | <input type="checkbox"/> Pumped | <input type="checkbox"/> Poured |

Gravel Pack: Yes No 55 to 80 Pumped Poured
Type: #8 Sand

Bentonite Chips: Yes No 50 to 55 Pumped Poured
Type: 3/8" Bentonite Chips

7. Water Level
Static water level: 63.5 feet below land surface
Artesian Flow: No G.P.M. N/A P.S.I.
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA

| | | | |
|--------------|---------------------------------|----------------------------------|-----------------------------------|
| TEST METHOD: | <input type="checkbox"/> Bailer | <input type="checkbox"/> Pump | <input type="checkbox"/> Air Lift |
| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
| | | | |
| | | | |
| | | | |

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eklund Drilling Company, Inc.
Contractor

Address PO Box 2748
Contractor

Elko, NV 89803

Nevada contractor's license number
issued by the State Contractor's Board 0030823

Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 1776

Signed Art Seelman
By driller performing actual drilling on site or contractor

Date 10/16/2008


210-I
MH-F

LOG# 110878

NEWMONT - NORTH AREA 4 1/2 TAILS

pg 2/2

MW-42 - 16-S (SHALLOW)



STATIC water level @ 63.5'

STATE ENGINEERS OFFICE

2008 OCT 20 PM 12:35

RECEIVED