STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110893
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32325

1. OWNER Glendale Holding Co., LLC
MAILING ADDRESS 1000 N. Green Valley Pkwy #440-350
Henderson, NV. 89074-6170

ADDRESS AT WELL LOCATION 2300 Glendale ~~Pkwy~~ Blvd.
Glendale, NV. 89025
~~Subdivision Name~~: Cl. well # VE-1 County: Clark

2. LOCATION NE ¼ NE ¼ Sec 2 T 15 N/S R 66 E
PERMIT/WAIVER No. — 042-02-501-009
Issued by Water Resources Parcel No.

Latitude N 36° 39' 55.5" UTM E ☐ NAD 27
Longitude W 114° 34' 09.5" N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill Silty Sand		0	4	4
Silt / Clay		4	11	7
Clayey Sand	yes	11	14	3

JOURNAL RECEIVED
APR 21 2010
LAS VEGAS OFFICE

Date started: 4/14/ , 20 10
Date completed: 4/14 , 20 10

9. WELL CONSTRUCTION
Depth Drilled 14 Feet Depth Cased 14 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8"	Inches	0 Feet	14 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4 inch	ASTM-F480 - Sch. 40		0	14

Perforations:
Type of perforation Factory Slots
Size of perforation 020
From 9 feet to 14 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 9 to 14 ☐ Pumped ☒ Poured
Type: #12 Silica Sand
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☒ Poured
Type: 3/8 Bentonite chips - Top to be plumbed into a Vapor Extraction System by others

7. Water Level
Static water level: 11.5 feet below land surface
Artesian Flow: NA G.P.M. P.S.I.
Water Temperature: Cool °F
Quality: Poor - Contaminated

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc
Contractor
Address 4255 W. Post Rd.
Contractor
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall
By driller performing actual drilling on-site or contractor
Date 4/16/10

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627