STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 110894
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32325

1. OWNER Glendale Holding Co., LLC
MAILING ADDRESS 1000 N. Green Valley Pkwy 440-350
Henderson, NV. 89074-6110

ADDRESS AT WELL LOCATION 2300 Glendale ~~Ave.~~ Blvd
Glendale, NV. 89025
Subdivision Name: Client Well # 5 County: Clark

2. LOCATION NE ¼ NE ¼ Sec 2 T 15 N OR 66 E
PERMIT/WAIVER No. — (Issued by Water Resources)
042-02-501-009 (Parcel No.)

Latitude N. 36° 36' 39.1"
Longitude W 114° 34' 09.0"
UTM E ..... N .....
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill 2" A/C over Agg. base		0	1	1
Fill Silty Sand		1	3	2
Silty Clay		3	11	8
Clayey Sand	yes	11	14	3

RECEIVED
DIVISION OF WATER RESOURCES
APR 21 2010
LAS VEGAS OFFICE

Date started: 4/14, 20 10
Date completed: 4/14, 20 10

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: NA. G.P.M. ..... P.S.I.
Water Temperature: Cool °F
Quality: Poor - Contaminated

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA.		

9. WELL CONSTRUCTION
Depth Drilled 14 Feet Depth Cased 14 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	14	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4" PVS	ASTM	450 sch. 40		

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 9 feet to 14 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement ..... to ..... ☐ Pumped ☐ Poured
☐ Cement Grout ..... to ..... ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 2 ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout ..... to ..... ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 9 to 14 ☐ Pumped ☐ Poured
Type: #12 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 2 to 9 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas N. Beall (By driller performing actual drilling on-site or contractor)
Date 4/16/10

(Rev 05-08)
USE ADDITIONAL SHEETS IF NECESSARY