

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33214

1. OWNER **RICHARD & CAROL BUSHART** ADDRESS AT WELL LOCATION **2771 LORELIE ST.**
 MAILING ADDRESS **2771 LORELIE ST.**
PAHRUMP, NV 89048

2. LOCATION **SE 1/4 NE 1/4 Sec. 12 T 21S** N/S R **53E E NYE** County
 PERMIT NO. **44-521-12** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
EXISTING 8" STEEL WELL		0	120	120
CLAY		120	135	15
CALICHIE	WB	135	150	15
CLAY		150	168	18
CALICHIE	WB	168	185	17
CLAY		185	203	18
CALICHIE	WB	203	250	47
CLAY		250	260	10
N36°08'24.5" W115°57'42.2"				

**DOWN
RECEIVED**

APR 14 2010

LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled **260** Feet Depth Cased **260** Feet

HOLE DIAMETER (BIT SIZE)
 EXISTING 8" From To
7 7/8 Inches **120** Feet **260** Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
EXISTING	STEEL		0	120
4 1/2	2.37	.248	0	260

Perforations:
 Type perforation **SAW**
 Size perforation **1/8 x 3**

From	160	feet to	260	feet
From		feet to		feet
From		feet to		feet
From		feet to		feet
From		feet to		feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **EXISTING** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **120** feet to **260** feet

Date started **4/12/2010**, 19
 Date completed **4/12/2010**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level **65** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor
 Address **1220 E MANSE RD** Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board **47333**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**
 Signed *[Signature]*
 By driller performing actual drilling on-site or contractor
 Date **4/13/2010**