STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111130
Permit No.
Basin 163

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35202

1. OWNER Drusilla A. Bale
MAILING ADDRESS 30042 Mission Blvd. #121-351 Hayward CA. 94544-7255

ADDRESS AT WELL LOCATION Oregon Av. & Maricopa Sandy Valley
Subdivision Name: County: Clark

2. LOCATION NE ¼ NE ¼ Sec 05 T 25 N/S R 57 E
PERMIT/WAIVER No. 219-05-501-005
Issued by Water Resources Parcel No.

Latitude 35° 48' 453
Longitude 115° 36' 285
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Rock & Gravel		0	40	40
Clay & Gravel		40	70	30
Cemented Gravel		70	78	8
Clay & Gravel		78	96	18
Rock & Gravel	W.B	96	200	104

Date started: 4-29, 20 10
Date completed: 6-3, 20 10

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½"	2.36	.248 PVC	0	200

Perforations:
Type of perforation Factory Screen
Size of perforation .032 inch x 4 Row
From 200 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 20 ft. to Surface ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 200 to 50 ☐ Pumped ☒ Poured
Type: 3/8 inch Pea Gravel
Bentonite Chips: ☒ Yes ☐ No 50 ft to 20 ft ☐ Pumped ☒ Poured
Type: 3/8 inch Baroid Hole Plug

7. Water Level
Static water level: 87 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budget Drilling Co. (Contractor)
Address P.O. Box 3505 Pahrump NV. 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 5-4-2010

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627