

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111135
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

1. OWNER TIMOTHY A. MARK ADDRESS AT WELL LOCATION 1427 W. FRONTIER ST
MAILING ADDRESS 5202 BEVERLY LN. EVERETT, WA. 98203 AMARGOSA VALLEY
Subdivision Name: VALLEY VIEW EST. County: NYE

2. LOCATION NW 1/4 NW 1/4 Sec 11 T 16 N R 48 E Latitude 36° 34' 9.17" UTM E NAD 27
PERMIT/WAIVER No. 19-671-33 Longitude 116° 32' 40.3" N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

NOTICE OF INTENT NO. 35199

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>SANDY LOAM + GRAVEL</u>		<u>0</u>	<u>105</u>	<u>105</u>
<u>CLAY + GRAVEL</u>		<u>105</u>	<u>125</u>	<u>20</u>
<u>CEMENTED SAND + GRAVEL</u>		<u>125</u>	<u>133</u>	<u>8</u>
<u>SAND - COARSE</u>	<u>WB</u>	<u>133</u>	<u>140</u>	<u>7</u>
<u>SAND + GRAVEL</u>	<u>WB</u>	<u>140</u>	<u>220</u>	<u>80</u>

9. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)
From 0 To 220
9 7/8 Inches Feet 220 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>2.36</u>	<u>248 PVC.</u>	<u>0</u>	<u>220</u>

Date started: 3-29 20 10
Date completed: 4-3 20 10

Perforations:
Type of perforation FACTORY SCREEN
Size of perforation 1.032 INCH X 6 ROW
From 220 feet to 140 feet
From _____ feet to _____ feet

7. Water Level
Static water level: 130 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COOL °F
Quality: _____

Annular Seal: Yes No
 Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout 20 to SURFACE Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 220 to 50 Pumped Poured
Type: FEA GRAVEL

Bentonite Chips: Yes No 50 to 20 Pumped Poured
Type: 3/8" INCH BAROID HOLE PLUG

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO Contractor
Address P.O. BOX 3505 PRATTVILLE NV. Contractor
89041
Nevada contractor's license number 40020
issued by the State Contractor's Board
Nevada driller's license number issued by the 1573
Division of Water Resources, the on-site driller
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 4-5-2010