

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 111147  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32312

1. OWNER Life style holding Inn rd. ADDRESS AT WELL LOCATION 2548 W. Desert Land  
MAILING ADDRESS 460 Arthur Godfrey rd #200 Las Vegas, NV  
Miami Beach, Florida 33140 Subdivision Name: \_\_\_\_\_ County: Clark  
2. LOCATION SE 1/4 SE 1/4 Sec 8 T 21 N R 61 E Latitude 36° 07' 58.9" UTM E \_\_\_\_\_  NAD 27  
PERMIT/WAIVER No. 162-08-805-009 Longitude 115° 10' 30.492" W  NAD 83/WGS 84

3. WORKED PERFORMED  New Well  Replace  Recondition  
 Deepen  Other  
4. PROPOSED USE  Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW-19</u>				
<u>Fill sand &amp; Gravel</u>		<u>0</u>	<u>2</u>	<u>2</u>
<u>Sandy clay</u>		<u>2</u>	<u>5</u>	<u>3</u>
<u>Caliche</u>		<u>5</u>	<u>7</u>	<u>2</u>
<u>Sandy clay</u>	<u>13</u>	<u>7</u>	<u>35</u>	<u>28</u>

9. WELL CONSTRUCTION  
Depth Drilled 35 Feet Depth Cased 35 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 35  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>Sch 40</u>	<u>0</u>	<u>35</u>

Perforations:  
Type of perforation Factory slot  
Size of perforation .020  
From 5' feet to 35' feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0.5 to 2  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured  
Gravel Pack:  Yes  No 4 to 35  
Type: #12 sand  
Bentonite Chips:  Yes  No 2 to 4  Pumped  Poured  
Type: 3/8 Hole plug

Date started: Dec 22 20 09  
Date completed: Dec 22 20 09

7. Water Level  
Static water level: 13 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: \_\_\_\_\_ °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer			
<input type="checkbox"/> Pump			
<input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Elite Drilling Inc.  
Address 4255 W. Post Rd.  
Las Vegas, NV 89118  
Nevada contractor's license number 0054931  
issued by the State Contractor's Board  
Nevada driller's license number issued by the M-1869  
Division of Water Resources, the on-site driller  
Signed \_\_\_\_\_  
Date 12-28-09

USE ADDITIONAL SHEETS IF NECESSARY