STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111175
Permit No. 58428 E
Basin 044

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64877-1

1. OWNER YUKON-NEVADA GOLD CORP
MAILING ADDRESS HC 31, BOX 78
ELKO, NV 89801

ADDRESS AT WELL LOCATION JERRITT CANYON MILL SITE
TAILINGS POND ***HOLE # DPE-15***
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION NE ¼ SE ¼ Sec 33 T 41N N/S R 54 E
PERMIT/WAIVER No. 58428E (Issued by Water Resources) 005-570-007 Parcel No.
Latitude 41.403089280 Longitude 115.890465317
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY w/ SAND		0	20	20
SAND w/GRAVEL	X	20	115	95
SAND w/ SILT & CLAY	XX	115	200	85
1st WATER @ 100'				
2nd WATER @ 160'				
CASING INSTALLED WITH PLASTIC CAP ON TOP & BOTTOM				
80' TO 82' BENTONITE PELLETS PLACED				
10" x 10.5' STEEL CASING MONUMENT w/ BLANK CAP INSTALLED IN A 3' x 3' x 6" CONCRETE PAD				

Date started: 8-Jun, 20 10
Date completed: 10-Jun, 20 10

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8	Inches	0 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		Sch 40 Monoflex thread	+1	195
10		.250	+1.5	9

Perforations:
Type of perforation FACTORY PERFORATED PLASTIC
Size of perforation 0.020 SLOT
From 87 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 10 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 15 to 80 [X] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 82 to 200 [ ] Pumped [X] Poured
Type: 3/8" WASH PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 10 to 15 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 38 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 40 °F
Quality: FAIR

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125 PSI @ 825 CFM	24		3.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 6/22/2010

STATE ENGINEERS OFFICE
2010 JUL -9 PM 1:26
RECEIVED

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

PLO. F