

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 111.179  
Permit No.           
Basin 044

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64879

1. OWNER YUKON-NEVADA GOLD CORP  
MAILING ADDRESS HC 31, BOX 78  
ELKO, NV 89801

ADDRESS AT WELL LOCATION JERRITT CANYON MILL SITE  
TAILINGS POND \*\*\*HOLE # GW-63\*\*\*  
Subdivision Name: PARCEL OF LAND County: ELKO

2. LOCATION SW 1/4 NW 1/4 Sec 34 T 41N N/S/R 54 E  
PERMIT/WAIVER No. NDP #NVE-00020 005-570-007  
Parcel No.         

Latitude 41.406170752 UTM E           NAD 27  
Longitude 115.888863131 N           NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
GRAVEL w/SAND & CLAY		0	40	40
GRAVEL w/ THICK CLAY		40	50	10
GRAVEL w/ SILT		50	80	30
FINE GRAVEL w/SILT & CLAY	X	80	120	40
FINE GRAVEL		120	130	10
COARSE GRAVEL w/ SAND & CLAY		130	150	20
1st WATER @ 115'				
CASING INSTALLED WITH PLASTIC CAP ON TOP & BOTTOM				
119' TO 123' BENTONITE PELLETS PLACED				
6" X 7' STEEL CASING MONUMENT w/ LOCKING CAP INSTALLED IN A 3' x 3' x 6" CONCRETE PAD				

9. WELL CONSTRUCTION				
Depth Drilled	150	Feet	Depth Cased	149
HOLE DIAMETER (BIT SIZE)				
	From		To	
	7 7/8	Inches	0	Feet 150
		Inches		Feet
		Inches		Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		Sch 40 Monoflex thread	+1	149
6.625	13	.188	+2	5

Perforations:  
Type of perforation FACTORY PERFORATED PLASTIC  
Size of perforation 0.020 SLOT  
From 129 feet to 149 feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet

Annular Seal:  Yes  No  
 Neat Cement 0 to 10  Pumped  Poured  
 Cement Grout          to           Pumped  Poured  
 Concrete Grout          to           Pumped  Poured  
 ≥30% Bentonite Grout 15 to 119  Pumped  Poured  
Gravel Pack:  Yes  No 123 to 150  Pumped  Poured  
Type: 3/8" WASH PEA GRAVEL  
Bentonite Chips:  Yes  No 10 to 15  Pumped  Poured  
Type: 3/8" BENTONITE CHIPS

Date started: 13-Jun 20 10  
Date completed: 14-Jun 20 10

7. Water Level  
Static water level: 79 feet below land surface  
Artesian Flow:          G.P.M.          P.S.I.  
Water Temperature: 58 °F  
Quality: POOR

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name HACKWORTH DRILLING, INC.  
Contractor  
Address P. O. BOX 850  
Contractor  
ELKO, NV 89803  
Nevada contractor's license number 020582  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1653  
Signed Jerry C. Ben  
by driller performing actual drilling on site or contractor  
Date 6/23/2010

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
125 PSI @ 825 CFM	2		2.75
STATE ENGINEERS OFFICE 27 JUL 9 11:27 AM '10			