

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 111193  
Permit No. -  
Basin 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64963-402E

1. OWNER A&K Earthmovers, Inc.  
MAILING ADDRESS P.O. Box 1059  
Fallon, NV 89407

ADDRESS AT WELL LOCATION Bottom Rd.  
Fallon, NV 89406  
Subdivision Name: \_\_\_\_\_ County: Churchill

2. LOCATION SW ¼ NE ¼ Sec 34 T 19N N/S R 28 E  
PERMIT/WAIVER No. DEW-82  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39.47097N UTM E  NAD 27  
Longitude -118.82764 W N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	5	5
Clay		5	18	13
Sand	XX	18	30	12
NAD - 27 GPS 39.471053°N 118.827653°W				

9. WELL CONSTRUCTION

Depth Drilled	30	Feet	Depth Cased	30	Feet
HOLE DIAMETER (BIT SIZE)					
	From	To			
22	Inches	0	Feet	30	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet
CASING SCHEDULE					
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)	
8.625	8.26	.508	0	30	

RECEIVED  
2010 JUL -8 AM 10:56  
STATE ENGINEER'S OFFICE

Perforations:

Type of perforation	Well Screen	
Size of perforation	0.032	
From	10	feet to 30 feet
From		feet to feet
From		feet to feet
From		feet to feet
From		feet to feet

Annular Seal:  Yes  No

<input type="checkbox"/> Neat Cement	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Cement Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input type="checkbox"/> Concrete Grout	to	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
<input checked="" type="checkbox"/> ≥30% Bentonite Grout	0 to 3	<input type="checkbox"/> Pumped	<input checked="" type="checkbox"/> Poured

Gravel Pack:  Yes  No 30 to 3  Pumped  Poured  
Type: 3/8 Well gravel

Bentonite Chips:  Yes  No to  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 1-Jun 20 10  
Date completed: 1-Jun 20 10

7. Water Level  
Static water level: 3 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: Cool °F  
Quality: Unknown

8. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Parsons Drilling, Inc. Contractor  
Address P.O. Box 1265 Contractor  
Fallon, NV 89407  
Nevada contractor's license number issued by the State Contractor's Board 29064  
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2307  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 6/24/2010