

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 11222  
Permit No. \_\_\_\_\_  
Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35143

1. OWNER CV Propco LLC %GenCounsel ADDRESS AT WELL LOCATION 3564 W. Naples Dr.  
MAILING ADDRESS 1505 S. Pavilion Center RW-2 Paradise nv  
Las Vegas, NV 89135 Subdivision Name: \_\_\_\_\_ County: Clark

2. LOCATION NW ¼ SW ¼ Sec 20 T 21S N/S R 61 E Latitude 36 06'25.67"N UTM E  NAD 27  
PERMIT/WAIVER No. 16220301010 Longitude 115 11'12.27"W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other  Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	5	5
Clayey Sand		5	7	2
Sandy Clay		7	10	3
Clayey Sand		10	12	2
Silty Clay		12	15	3
Caliche		15	16	1
Silty Clay		16	20	4
Sandy Clay		20	26	6
Silty Clay		26	32	6
Caliche		32	34	2
Sandy Clay		34	43	9

9. WELL CONSTRUCTION

Depth Drilled 43 Feet Depth Cased 43 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
<u>10</u> Inches	<u>0</u> Feet	<u>43</u> Feet
_____ Inches	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>Sch 40</u>	<u>0</u>	<u>43</u>

Perforations:

Type of perforation Factory Slotted

Size of perforation .020

From 23 feet to 43 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 21 to 43  Pumped  Poured  
Type: #3 Monterey Sand

Bentonite Chips:  Yes  No 1 to 21  Pumped  Poured  
Type: Medium Bentonite Chips

7. Water Level  
Static water level: 32.5 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: n/a °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>.5</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WDC Exploration & Wells  
Contractor

Address 570 Corinthian Way  
Contractor

N. Las Vegas, NV, 89030

Nevada contractor's license number issued by the State Contractor's Board 0012852

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2381

Signed [Signature]  
By driller performing actual drilling on site or contractor

Date 12-28-09