STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111224
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35300

1. OWNER Argyris Enterprises LLC 80%, Argyris joann 20%
MAILING ADDRESS 9948 Keifer Valley St
Las Vegas, NV 89178-4823

ADDRESS AT WELL LOCATION 6495 S. Pecos Rd
MW-1
Subdivision Name: County: Clark

2. LOCATION SE ¼ SE ¼ Sec 36 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-36-802-023
Issued by Water Resources Parcel No.

Latitude 36.041883
Longitude 115.060412
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	1	1
Sandy Silt		1	6	5
Silt		6	10	4
Clay		10	12	2
Gravelly Silt		12	15	3
Clayey Silt		15	19	4
Silty Clay		19	25	6

Date started: 15-Apr , 20 10
Date completed: 15-Apr , 20 10

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	25	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	25

Perforations:
Type of perforation Factory Slotted
Size of perforation .020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 3 to 25 ☐ Pumped ☒ Poured
Type: #3 Montery Sand
Bentonite Chips: ☒ Yes ☐ No 1 to 3 ☐ Pumped ☒ Poured
Type: 3/4 Bentonite Chips

7. Water Level
Static water level: 11.81 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
N. Las Vegas, NV, 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources the *on-site driller* M-2381
Signed
By driller performing actual drilling on site or contractor
Date 5-11-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY