DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Log No. 111293
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32473

1. OWNER Los Olivos Partner llc
MAILING ADDRESS 102 N Milpas ST Santa Barbara CA 93103

ADDRESS AT WELL LOCATION 34 Grand Cornicke Dr
Subdivision Name:
County: Clark

2. LOCATION NE¼ SE ¼ Sec 22 T 21 N/S R 63 E
PERMIT/WAIVER No. 160-22 710 007
Issued by Water Resources
Parcel No.

Latitude 36 06 24 24
Longitude 114 55 24 46
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other H.S.A.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
gravel and sand		0	2'	2'
sandy and gravel		2'	9	7'
sandy and clay		9	15	6'
sand gravel		15	21	5'
gravel sand and cobb		21	30	9

Date started: 2-2, 20 10
Date completed: 2-2, 20 10

7. Water Level
Static water level: 7'-8" feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8"	Inches	0 Feet	30 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	40 Sch	0	29

Perforations:
Type of perforation PVC Screen
Size of perforation 0.020
From 4' feet to 29' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout 0 to 2' ☐ Pumped ☒ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ =30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4' to 30 ☐ Pumped ☒ Poured
Type: Cency Sand 2x16
Bentonite Chips: ☒ Yes ☐ No 2' to 4' ☐ Pumped ☒ Poured
Type: Bentonite 3/8 chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Eagle Drilling services
Address (Contractor) 7150 Placid Street
Las Vegas NV 89119
Nevada contractor's license number issued by the *State Contractor's Board* 51266
Nevada driller's license number issued by the Division of Water Resources, the ~~on-site driller~~ 2097
Signed (By driller performing actual drilling on site or contractor)
Date 2-8-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

RECEIVED FEB 10 2010 LAS VEGAS OFFICE