STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111269
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 32476

1. OWNER 7-ELEVEN INC. C/O AV TAX DEPT. #0125
MAILING ADDRESS PO BOX 711 DALLAS TX 75221

ADDRESS AT WELL LOCATION 1705 S. LAS VEGAS BLVD LAS VEGAS NV.
Subdivision Name: County: CLARK

2. LOCATION NW ¼ SW ¼ Sec 03 T 21 N/S R 61 E
PERMIT/WAIVER No. 162-03-310-001
Issued by Water Resources Parcel No.

Latitude 36° 09 02 98 N
Longitude 115° 09 03 45 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0'	.25'	.25
SAND + GRAVEL FILL		.25'	1.0'	.75
BROWN SILTY SAND		1.0'	5.0'	4.0
MOIST BROWN CLAY		5.0	9.0'	4.0
CALCHE		9.0'	11.0'	2.0
GRAY SILTY CLAY	YES	11.00	25'	14
MW15				
FACILITY ID NO.				
8-000615				

Date started: 3-30-2010 , 20 10
Date completed: 3-30-2010 , 20 10

7. Water Level
Static water level: 14.5' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DOWN/DWR RECEIVED APR 06 2010 LAS VEGAS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	26	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	24

Perforations:
Type of perforation MACHINE SLOT
Size of perforation .020
From 9 feet to 24 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

		to			
☐ Neat Cement			☐ Pumped	☐ Poured
☒ Cement Grout	1	7	☐ Pumped	☒ Poured
☐ Concrete Grout	0	1	☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout			☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 7 to 25 ☐ Pumped ☒ Poured
Type: NO 3
Bentonite Chips: ☒ Yes ☐ No 7 to 9 ☐ Pumped ☒ Poured
Type: 3/8"

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EAGLE DRILL INC (Contractor)
Address 7150 PLACID ST LAS VEGAS NV. 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2357
Signed Neil L Wilkins
By driller performing actual drilling on-site or contractor
Date 3-31-2010

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY