

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111279
Permit No. _____
Basin _____

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35200

1. OWNER NANCY L. KNIGHT ADDRESS AT WELL LOCATION 2985 CHEROKEE ST
MAILING ADDRESS HCR. 37 Box 640 SANDY VALLEY NV
SANDY VALLEY NV. 89019 Subdivision Name: _____ County: CLARK

2. LOCATION SE 1/4 SE 1/4 Sec 16 T 25 N R 57 E Latitude 35 45.957 UTM E NAD 27
PERMIT/WAIVER No. 219-16-801-010 Longitude 115 35.076 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>EXISTING 8" STEEL</u>		<u>0</u>		
<u>CASING</u>			<u>45</u>	<u>45</u>
<u>CLAY + GRAVEL</u>		<u>45</u>	<u>52</u>	<u>7</u>
<u>SAND + GRAVEL</u>	<u>W.B</u>	<u>52</u>	<u>65</u>	<u>13</u>
<u>CLAY + GRAVEL</u>		<u>65</u>	<u>81</u>	<u>16</u>
<u>SAND + GRAVEL</u>	<u>W.B</u>	<u>81</u>	<u>94</u>	<u>13</u>
<u>CLAY + GRAVEL</u>		<u>94</u>	<u>105</u>	<u>11</u>
<u>SAND + GRAVEL</u>	<u>W.B</u>	<u>105</u>	<u>115</u>	<u>10</u>
<u>CLAY + GRAVEL</u>		<u>115</u>	<u>120</u>	<u>5</u>

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
From 7 7/8 Inches To 120 Feet
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>2.36</u>	<u>248 PVC</u>	<u>0</u>	<u>120</u>

Perforations:
Type of perforation FACTORY SCREEN
Size of perforation .032" INCH X 4" ROW
From 120 feet to 6.0 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement to EXISTING Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 120 to 50 Pumped Poured
Type: 3/8" INCH PEA GRAVEL
Bentonite Chips: Yes No 50 to 0 Pumped Poured
Type: 3/8" INCH BAROID HOLE PLUG

Date started: 4-14 20 10
Date completed: 4-16 20 10

7. Water Level
Static water level: 44 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COOL °F
Quality: _____

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
G.P.M.		Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BUDGET DRILLING CO. Contractor
Address P.O. Box 3505 Prater NV. Contractor
89041
Nevada contractor's license number _____
issued by the State Contractor's Board 40020
Nevada driller's license number issued by the _____
Division of Water Resources, the on-site driller 1573
Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 4-20-2010

USE ADDITIONAL SHEETS IF NECESSARY