

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 111301  
Permit No. 17392  
Basin 030A

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64419

1 OWNER KINGS RIVER RANCH ADDRESS AT WELL LOCATION KING RIVER RANCH  
MAILING ADDRESS 129 KINGS RIVER RD. CAROLINA, NV. 89425  
CAROLINA, NV. 89425 Subdivision Name: A-1 County: HUMBOLDT

2 LOCATION NE 1/4 NE 1/4 Sec 15 T 46 N/S R 33 E Latitude N 41° 52' 21.3" UTM E  NAD 27  
PERMIT/WAIVER No. 17392 Longitude W 118° 14' 47.4" N  NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? Is there an existing well log?  
 Domestic  Irrigation  Test NO YES  
 Municipal/Industrial  Monitor  Stock If yes, what is replacement well NOI? If yes, what is NDWR well log #? 7204

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 368 Feet Depth Cased 368 Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>		<u>3/16</u>	<u>368</u>	<u>0</u>

Existing Perforations:  
Type of perforation SAW SLOT  
Size of perforation 3/8 x 2  
From 300 feet to 350 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no

If well was not cleaned out to total depth, please explain why:  
\_\_\_\_\_  
\_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

If casing was left in place, please show where additional perforations were made:  
Additional Perforations:

Type of perforator used: MILLS KNIFE  
From 300 feet to 100 feet Number of perms per linear foot 4  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From 50 feet to 0 feet Number of perms per linear foot 4  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet Number of perms per linear foot \_\_\_\_\_

5 WATER LEVEL  
Static water level 106 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

Material Used  
From 368 feet to 60 feet T.C. BENTONITE  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  Pumped  Poured  
From 60 feet to 50 feet CLAY CHIPS  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  Pumped  Poured  
From 50 feet to 0 feet HEAT CEMENT  Pumped  Poured  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  Pumped  Poured

Neat Cement Fluid Weight lbs/gal 12.4 - 12.6  
Bentonite Grout 30% bentonite T.C. GROUT

Date Started 5-24-10  
Date Completed 7-21-10

6 Additional Notes or Comments  
370 BAGS T.C. BENTONITE  
FROM 368 - TO 60  
10 BAGS VOLCLAY CHIPS  
60 - 50  
50 100# BAG CEMENT  
50 TO 0

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name KINGS RIVER RANCH Contractor  
Address 129 KINGS RIVER RD Contractor  
CAROLINA, NEVADA 89425

Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1712

Signed Mike W. Drinch  
By driller performing actual drilling on site or contractor  
Date 7-25-10

THIS WELL TOOK A LOT OF MUD  
WE WOULD BRING IT UP AND LET  
IT SETTLE AND IT WOULD SETTLE  
BACK TO AROUND 90' ALOT OF  
TIME.  
THE T.C. 30% GROUT PUMPS REALLY  
WELL SO IT GOES PRETTY FAST