

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 111303
Permit No. _____
Basin 153

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65901

1 OWNER Ruby Hill Mine ADDRESS AT WELL LOCATION Junction Hwy 50 and SR278
MAILING ADDRESS P.O. Box 676 2 miles west of Eureka, NV.
Eureka, NV. 89316 Subdivision Name: _____ County: Eureka

2 LOCATION NE 1/4 SE 1/4 Sec 10 T 20N N/S R 53 E Latitude 39 31' 45.50N UTM E NAD 27
PERMIT/WAIVER No. _____ Longitude 115 59' 6.16W N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? _____
If yes, what is replacement well NOI? _____
Is there an existing well log? yes
If yes, what is NDWR well log #? 64514

4 EXISTING WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

EXISTING CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 4" | | .237 | +2' | 725 |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Existing Perforations:

| Type of perforation | mill slot |
|---|-------------|
| From <u>680</u> feet to <u>700</u> feet | <u>0.01</u> |
| From _____ feet to _____ feet | |
| From _____ feet to _____ feet | |
| From _____ feet to _____ feet | |
| From _____ feet to _____ feet | |

5 WATER LEVEL
Static water level 703.9 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

6 Additional Notes or Comments

NAME: MW-6

Removed 672' of 3/4" sounder tube and 672' of 3/4" drop pipe with 1-1/2 hp pump from MW-6. Measured static water level at 703.9' and depth of well at 715'. Installed 1-1/4" tremmie pipe into 4" casing and blew debris out to a depth of 725'. We then mixed approximately 700 gallons of abandonment gel and pumped through tremmie pipe from bottom of well to surface. We allowed the well to set idle overnight for the gel to settle. The following morning we measured the top of the gel at 22'. We mixed neat cement and pumped in from 22' to the surface.

NAD-27 GPS
39.529377°N
115.984153°W

STATE ENGINEERS OFFICE
2010 JUL 29 AM 11:56

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

If casing was left in place, please show where additional perforations were made:
Additional Perforations:

Type of perforator used: could not perforate 4" casing

| From | feet to | feet | Number of perfs per linear foot |
|------------|---------------|------|---------------------------------|
| From _____ | feet to _____ | feet | _____ |
| From _____ | feet to _____ | feet | _____ |
| From _____ | feet to _____ | feet | _____ |
| From _____ | feet to _____ | feet | _____ |
| From _____ | feet to _____ | feet | _____ |
| From _____ | feet to _____ | feet | _____ |

8 WELL PLUGGING MATERIALS

| From | feet to | feet | Material Used | <input checked="" type="checkbox"/> Pumped | <input type="checkbox"/> Poured |
|-----------------|--------------------|------|-----------------------|--|---------------------------------|
| From <u>20'</u> | feet to <u>725</u> | feet | <u>abandonite gel</u> | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| From _____ | feet to _____ | feet | | <input type="checkbox"/> | <input type="checkbox"/> |
| From _____ | feet to _____ | feet | | <input type="checkbox"/> | <input type="checkbox"/> |
| From _____ | feet to _____ | feet | | <input type="checkbox"/> | <input type="checkbox"/> |
| From _____ | feet to _____ | feet | | <input type="checkbox"/> | <input type="checkbox"/> |
| From _____ | feet to _____ | feet | | <input type="checkbox"/> | <input type="checkbox"/> |

Neat Cement Fluid Weight _____ lbs/gal
Bentonite Grout 12.3 % bentonite
Date Started 14-Jul-10
Date Completed 15-Jul-10

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721

Nevada contractor's license number 39920A
issued by the State Contractor's Board

Nevada driller's license number issued by the 1482
Division of Water Resources, the on-site driller

Signed [Signature]
By driller performing actual drilling on site or contractor

Date 7/24/2010

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

P.O.F.