STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111339
Permit No.
Basin 0926

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 49246 (1)

1. OWNER LANE GROW
MAILING ADDRESS SAME

ADDRESS AT WELL LOCATION 2645 MARGARET DR,RENO,NV.89506
GOLDEN VALLEY
Subdivision Name: MEDALLION County: WASHOE

2. LOCATION SE ¼ NW ¼ Sec 10 T 20N N/S R 19 E
PERMIT/WAIVER No. 552-175-09
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 0256575 [X] NAD 27
N 4388888 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light brown (hard)		0	45	
Dark brown with clay (soft)	51	45	52	7
Dark gray (hard) & fractured		52	90	38
Dark gray (fractured)		90	145	55

replaces original log #13567 which which was plugged under log #111447 NOI#49249

39.617,046°N NAD27 D.D
119.835,684°W

Date started: 05-10- , 20 10
Date completed: 7-Jun , 20 2010

7. Water Level
Static water level: 48 feet below land surface
Artesian Flow: NONE G.P.M. N/A P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
BAILER	20	31	1

9. WELL CONSTRUCTION
Depth Drilled 145 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	145	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.250	0	145

Perforations:
Type of perforation factory
Size of perforation 1/8"X 4"
From 100 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[ ] Neat Cement to [ ] Pumped [ ] Poured
[X] Cement Grout 0 to 55 [X] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 145 [ ] Pumped [X] Poured
Type: 3/8" pea gravel
Bentonite Chips: [ ] Yes [X] No to [ ] Pumped [ ] Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WILLIAM GEORGE MOSEGAARD WELL DRILLING
Contractor
Address P.O.BOX 61075,RENO,NV.89506
Contractor

Nevada contractor's license number issued by the *State Contractor's Board* 53579
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2211

Signed William George Mosegaard
By driller performing actual drilling on site or contractor
Date 6/19/2010

(Rev. 02-08)

USE ADDITIONAL SHEETS IF NECESSARY

MMH · (E)