

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 111344  
 Permit No. \_\_\_\_\_  
 Basin 092A

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60633

1. OWNER **Dave Wilson** ADDRESS AT WELL LOCATION **10180 Placerville Rd.**  
 MAILING ADDRESS **10180 Placerville Rd. Reno, NV.** **Reno, Nv. 89506**  
 NE **Subdivision Name: N/A** **County: Washoe**

2. LOCATION **SE 1/4 Sec 13 T21N R18E** Latitude **39.68717** UTM E  NAD 27  
 PERMIT/WAIVER NO. **N/A** Parcel No. **86-250-72** Longitude **119.90487** N  NAD 83/WGS 84  
*Issued by Water Resources*

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other **Mud**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG		0	80	80
Gravel		80	100	20
DG		100	160	60
Course Sand		160	190	30
Grey/Brown Clay		190	640	450
Grey Sandstone	X	640	720	80
Grey Clay		720	740	40
Grey sandstone	X	740	780	40
Grey Clay		780	800	20

39.687, 261°W NAD27 DD.  
 119.903, 84°W

9. WELL CONSTRUCTION

Depth Drilled **800** Feet Depth Cased **800** Feet

HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
**12 1/4"** Inches **0** Feet **50** Feet  
**12 1/4"** Inches **50** Feet **800** Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<b>8 5/8" steel</b>	<b>17</b>	<b>.188</b>	<b>-1</b>	<b>800</b>

Perforations:  
 Type of perforation **Factory**  
 Size of perforation \_\_\_\_\_  
 From **640** feet to **700** feet  
 From **740** feet to **780** feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No **58** to **800**  Pumped  Poured  
 Type: **3/8 pea**  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **5/23, 20 08**  
 Date completed: **7/20, 20 08**

7. Water Level

Static water level: **140** feet below land surface  
 Artesian Flow: **None** G.P.M. **None** P.S.I  
 Water Temperature: **Cool** °F  
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<b>Approx</b>	<b>50</b>	<b>260</b>	<b>4 hrs</b>
	<b>35</b>	<b>219</b>	<b>72 hrs</b>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Miller & Son's Drilling, LLC** (CONTRACTOR)  
 Address **P.O. Box 8056** (CONTRACTOR)  
**Reno, NV. 89507**  
 Nevada contractor's license number issued by the State Contractor's Board **37915**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1418**

Signed Bruce Miller  
 By driller performing actual drilling on site or contractor  
 Date **7/30/2008**

MMH - F