STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11349
Permit No.
Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65984 (i)

1. OWNER Kerry Moss
MAILING ADDRESS 685 Dove Street Winnemucca, NV

ADDRESS AT WELL LOCATION 685 Dove Street Winnemucca, NV 89445
Subdivision Name: Burns Acres County: Pershing

2. LOCATION NE ¼ SW ¼ Sec 07 T 34 N/ R 38 E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 009-433-05 (Parcel. No.)

Latitude 40°50.021 UTM E ☐ NAD 27
Longitude 117°44.918 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	15	15
Gravel		15	20	5
Boulders/Gravel		20	42	22
Gravel/Sand		42	60	18
Clay		60	70	10
Gravel,course	X	70	90	20
Clay		90	95	5
Sand/Gravel/Cobbles	X	95	130	35
Clay		130	135	5
Cobbles/Gravel	X	135	140	5

see plugging report for original well - NOI # 65982

40.833,779°N NAD27 O.D.
117,747,671°W

Date started: July 1, 20 10
Date completed: July 6, 20 10

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	.188	+1	20
6.625	4.06	.316	20	140

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 050
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 30 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 50 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 30 to 50 ☐ Pumped ☒ Poured
Type:

7. Water Level
Static water level: 79 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Airlift	20		2
pumped	30		3

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc.
By driller performing actual drilling on site or contractor
Date July 8, 2010

MMH - (F)