STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111355
Permit No.
Basin 129

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65981 (1)

1. OWNER Alissa Walton / Joan Schneider
MAILING ADDRESS PO Box 1030 Imlay, NV 89418

ADDRESS AT WELL LOCATION 14300 Hwy 400
Imlay
Subdivision Name: Mary Sterling Parcel #7 County: Pershing

2. LOCATION SE ¼ NW ¼ Sec08T30N/ R35E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 012-062-02 (Parcel. No.)

Latitude 40°29.223 UTM E ☐ NAD 27
Longitude 118°04.263 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/rust		180	205	25
fracture rock	X	205	215	10
Clay & rock		215	220	5
sand/gravel	X	220	255	35
cobles/sand		255	265	10

40.487, 142°N NAD27 O.D.
118.070, 078°W

Date started: June 21, 20 10
Date completed: June 22, 20 10

7. Water Level
Static water level: 185 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

9. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	180 Feet	265 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	.188	165	265

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32 X 4
From 225 feet to 265 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date July 1, 2010

RECEIVED 2010 JUL -2 AM 11:44 STATE ENGINEER'S OFFICE

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MMH-(F)