REPORT NO. AB10.18

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 111362
PERMIT NO.
BASIN 104

NOTICE OF INTENT NO. 64311 (i)

1. OWNER State of NV Department of Transportation
MAILING ADDRESS 1263 S. Stewart Str. #313 Carson City, NV 89712
ADDRESS OF WELL 5049 Center Drive
Carson City, Nv 89712

2. WELL LOCATION ~~SW~~ (SW) ck 1/4 ~~NE~~ (NE) ck 1/4 SEC. ~~32~~ (32) ck T 15 R 20 E Carson City COUNTY

PERMIT NO 10-0000341 PARCEL NO 009-218-04 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
39.121,352 °N NAD27 D.D.				
119.759,901 °W				

RECEIVED 2010 JUL -1 AM 11:22 STATE ENGINEER'S OFFICE

Notes: WGS-84GPS:Lat.:N.39 degrees ~~8.856'~~ 7.275' Long.:W.119 degrees 45.654' ~~44.754'~~. Well cleaned out to total depth. Casing would not pull. Materials Used: 6 Bags of Grout & 2 Bags of Cement. Todd Alfrey - approved plugging in place. State Eng. unable to locate original log.

Date Started 5/21/2010 Date Completed 5/21/2010

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)

8. WELL CONSTRUCTION

Depth Drilled _____ Depth Cased _____

HOLE DIAMETER (BIT SIZE)
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet
_____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
4 1/2"	10.79	.250	+1	102

PERFORATIONS:
Type Perforation _____ Size Perforation _____
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet
From _____ Feet to _____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth _____
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From _____ Feet to _____ Feet

9. WATER LEVEL
Static Water Level 60 Feet Below Land Surface
Artesian Flow _____ GPM _____ PSI
Water Temperature Cold F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.
Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, Nv. 89502
NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2362
Signed [signature]
By driller performing actual drilling on site or contractor
Dated June 18, 2010

MMH - (F)