

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**  
Log No. 111376  
Permit No. -  
Basin 105

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 65903

1 OWNER Douglas County Community Development ADDRESS AT WELL LOCATION Douglas County Airport  
MAILING ADDRESS P.O. Box 218  
Minden, NV. 89423 Subdivision Name: \_\_\_\_\_ County: Douglas

2 LOCATION SW 1/4 SE 1/4 Sec 8 T 13N N/S R 20 E Latitude 39 00.024N UTM E  NAD 27  
PERMIT/WAIVER No. \_\_\_\_\_ Longitude 119 45.425W N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3 TYPE OF WELL  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
Is this well being plugged because a replacement well was drilled? no  
If yes, what is replacement well NOI? \_\_\_\_\_  
Is there an existing well log? n/a  
If yes, what is NDWR well log #? \_\_\_\_\_

4 EXISTING WELL CONSTRUCTION

Depth Drilled	<u>246'</u> Feet	Depth Cased	<u>246'</u> Feet
---------------	------------------	-------------	------------------

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5"</u>		<u>.188"</u>	<u>+2'</u>	<u>246'</u>

7 WELL PLUGGING PROCEDURE

Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why: \_\_\_\_\_

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

Existing Perforations:

Type of perforation	Size of perforation	From	feet to	feet
	<u>n/a</u>			
	<u>n/a</u>			

Additional Perforations:

Type of perforator used:

From	feet to	feet	Number of perfs per linear foot

5 WATER LEVEL

Static water level 6.12' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ ° F Quality \_\_\_\_\_

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
	<u>2'</u>	<u>246'</u>	<u>neat cement</u>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

Measured static water level at 6.12' and depth of well to 240'  
Installed 1-1/4" tremme pipe and blew well from 240 to 246'  
where we hit a hard bottom. Since well was cased with 5" casing, we could not perforate casing. We had tremme pipe installed to a depth of 241'. We then mixed 50 sacks of Portland Type II cement with approx. 250 gallons of water and pumped in through tremme pipe from bottom of well to surface. The well actual volume should have required approx 34 cu. Ft. but actually 50 cubic ft.

NAD-27 GPS  
39.000492° N  
119.756072° W

STATE ENGINEER  
00:11:00 08 MAR 2010

Neat Cement Fluid Weight 14.8 lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite  
Date Started 7/21/2010  
Date Completed 7/21/2010

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Carson Pump, LLC Contractor  
Address P.O. Box 20159 Contractor  
Carson City, NV. 89721

Nevada contractor's license number issued by the State Contractor's Board 39920A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed *Paul Franze* By driller performing actual drilling on-site or contractor  
Date 7/22/2010