STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111393
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64691

1. OWNER Andy Fisher
MAILING ADDRESS 6287 Westwind Way
Fallon, NV 89406

ADDRESS AT WELL LOCATION 6287 Westwind Way
Fallon, NV 89406
Subdivision Name: County: Churchill

2. LOCATION NW ¼ SE ¼ Sec 19 T 19N N/S R 28 E
PERMIT/WAIVER No. Issued by Water Resources
Parcel No. 008-152-12

Latitude 39.49413
Longitude -118.88109
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	12	12
Brown Clay		12	24	12
Black Clay		24	52	28
Black Sand		52	64	12
Brown Clay		64	72	8
Brown Sand		72	92	20
Gray Clay		92	110	18
Gray Sand		110	128	18
Brown Clay		128	135	7
Brown Sand	X	135	140	5

39.494, 214°N NAD 27 D.D.
118.880, 101°W

Date started: 17-Nov, 20 09
Date completed: 11/017, 20 09

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	18
6	4.0	.316	18	140

Perforations:
Type of perforation Well Screen
Size of perforation 0.032
From 137 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	10 to 0	☒ Pumped	☐ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	120 to 10	☐ Pumped	☒ Poured

Gravel Pack: ☒ Yes ☐ No 120 to 140 ☐ Pumped ☒ Poured
Type: 3/8" pea gravel
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 12 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cool °F
Quality: unknown

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	15	1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon,NV 89407
Nevada contractor's license number issued by the *State Contractor's Board* 29064
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2307
Signed (driller performing actual drilling on site or contractor)
Date 12/9/2009

(Rev. 06-08)
USE ADDITIONAL SHEETS IF NECESSARY

MMH - F