STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111410
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65585

1. OWNER MIKE PINGRAM / AMT Investments LP
MAILING ADDRESS 958 HEAVENLY VIEW CT
GARDNERVILLE, NV 89460

ADDRESS AT WELL LOCATION NOT GIVEN YET APN 1220-17-501-027
GARDNERVILLE, NV 89460 / 950 Heavenly View Ct
Subdivision Name: County: Douglas

2. LOCATION NW ¼ NE ¼ Sec 17 T 12N N/S R 20 E
PERMIT/WAIVER No. 1220-17-501-027
Issued by Water Resources Parcel No.

Latitude 38°54'34"N
Longitude 119°45'585"W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN		0	3	3
COBBLES AND GRAVELS		3	42	39
1/4 GRAVELS		42	83	41
COBBLES				
COURSE GRAVELS				
SMALL SSANDS		83	117	34
SMALL SILTY SANDS		117	138	21
FRACTURED COBBLES	XXX	138	180	42
GRAVELS				

38.910,660° N NAD27 D.D.
119.258,739° W

Date started: 12-Jul, 20 2010
Date completed: 14-Jul, 20 2010

9. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.250	.188	+2	180

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation 3 X 3/32
From 140 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☒ Cement Grout	0 to 100		☒ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to		☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 180 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35+	35	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address # 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed (By driller performing actual drilling on site or contractor)
Date 07/19/2010

STATE ENGINEER
2010 JUL 21 AM 11:36

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

MMH-(F)