

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63564 (1)

1. OWNER Curt Ashley ADDRESS AT WELL LOCATION 5552 Echo Dam Road Prichard NV 89045  
 MAILING ADDRESS 5715 Golden Springs Ave Las Vegas NV 89146  
 2. LOCATION S. E. 1/4 SW 1/4 Sec 36 T. 1 S. R. 68 E Lincoln County  
 PERMIT NO. 06-301-36 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand- Gravel		0	30	30
Clay		30	110	80
SAND- clay	X	110	120	10
Clay		120	185	65
gravel- clay	X	185	190	5
Clay		190	195	5

GPS WGS 84  
 N 37° 53.913'  
 W 114° 18.587'

37.898, 587° N NAD27 D.D.  
 114.308, 963° W

8. WELL CONSTRUCTION  
 Depth Drilled 195 Feet Depth Cased 195 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 125 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>125</u>

 Perforations:  
 Type perforation 5 jaw cut  
 Size perforation 1/8" x 3"  
 From 80' feet to 125 feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Depth of Seal 50'  
 Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 125 feet

Date started 6-19-2010, 20  
 Date completed 6-24-2010, 20

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>6</u>	<u>10</u>	<u>2</u>

2010 JUN 21 6:11:37

9. WATER LEVEL  
 Static water level 105 feet below land surface  
 Artesian flow 0 G.P.M. P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Davis Drilling and Pumps Contractor  
 Address HC 61 Box 54 Hiko NV 89007 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0028266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1121  
 Signed Mike Davis  
 By driller performing actual drilling on site or contractor  
 Date 6-25-2010