STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 11414
Permit No.
Basin 072A

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65048

1. OWNER Gerardo Rodrigueze
MAILING ADDRESS P.O. Box 462
Battle Mt. NV 89820

ADDRESS AT WELL LOCATION 32 nd Street
Elko, NV 89801

2. LOCATION SE ¼ NE ¼ Sec 31 T 34N N/S R 55 E
PERMIT/WAIVER No. 064-005-006
Issued by Water Resources — Parcel No.

Latitude 40 47. 507N
Longitude 115 49 042W
UTM E N Elko
☐ NAD 27 ☒ NAD 83/WGS 84
Subdivision Name: Meadow Valley Ranchos County: Elko

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other...

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Brown Clay		3	15	12
Cemented Gravel		15	37	22
Conglomerate		37	46	9
Brown Clay	X	46	93	47
Sandstone		93	96	3
Soft Sandstone		96	98	2
Sandstone		98	125	27
Soft Sandstone	X	125	127	2
Brown Clay		127	133	6
Sandstone	X	133	150	17
LD. 791, 862" W NAD 27 D.D.				
LS. 816, 464" W				

Date started 5-Jul , 20 10
Date completed 5-Jul , 20 10

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	55		2.5

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	150	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+2	150

Perforations:
Type of perforation Mill Slot
Size of perforation 3/16" x 3"
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 45
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 150 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig Sr., dba Fertig Drilling Company (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 031904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on site or contractor)
Date 8-14-10

(Rev. 08/10)

USE ADDITIONAL SHEETS IF NECESSARY

STATE ENGINEER'S OFFICE
2010 JUL 21 A 11:36
RECEIVED

MMH-F