STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111430
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65698

1. OWNER Jose Correa — phone: (801) 719-0797
MAILING ADDRESS 1400 Mountain City Hwy Space 105
Elko, NV 89801

ADDRESS AT WELL LOCATION Raven Rd, Lot 6 Block 0
Subdivision Name: Last Chance Ranch 3 County: Elko

2. LOCATION SW ¼ SW ¼ Sec 32 T 35N N/S R 56 E
PERMIT/WAIVER No. 032-01-5006 (Issued by Water Resources) Parcel No.
Latitude W 115*41.868 Longitude N 40*52.333
UTM E N
[X] NAD 27 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	2	2
sand & gravel		2	12	10
silt stone		12	120	108
blue clay		120	240	120
silt stone	250	240	330	90
	310			

40.872,217°N NAD27 D.D.
115.697,800°W

Date started: 12-Apr , 20 10
Date completed: 17-Apr , 20 10

7. Water Level
Static water level: 160 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		6

STATE ENGINEERS OFFICE
2010 MAY 17 AM 11:11
RECEIVED

9. WELL CONSTRUCTION
Depth Drilled 330 Feet Depth Cased 330 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	inches	0	Feet	280	Feet
6 1/8	inches	280	Feet	330	Feet
	inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	280
5		.088	270	330

Perforations:
Type of perforation: mill slot
Size of perforation: 3/16 x 3
From 260 feet to 280 feet
From 320 feet to 330 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 5 to 15 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured
Gravel Pack: [X] Yes [ ] No 50 to 280 [ ] Pumped [X] Poured
Type: pea gravel
Bentonite Chips: [X] Yes [ ] No 15 to 50 [ ] Pumped [X] Poured
Type: 3/8 chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): Alternative Drilling
Address (Contractor): P.O. Box 281166
Lamoille, NV 89828
Nevada contractor's license number issued by the State Contractor's Board: 73955
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1639
Signed (By driller performing actual drilling on site or contractor): Dan Nance
Date: 5-14-2010

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

MMH - E