

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64800 ①

1. OWNER Jim Westensee ADDRESS AT WELL LOCATION 8885 Diamond Dr.  
MAILING ADDRESS P.O. Box 2080 Winnemucca NV. 89446 Winnemucca NV. 89445  
2. LOCATION NE 1/4 SW 1/4 Sec 10 T. 37 S. R. 38 E Humboldt County Delaney  
PERMIT NO. 066-612-43 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Clay	NO	0	5	5
Caliche	NO	5	50	45
Lava Rock	Yes	50	68	18
Dark Clay & Gravel	Yes	68	88	20
Grey Clay & Gravel	Yes	88	108	20
Clay	NO	108	114	6
Gravel	Yes	114	120	6

GPS  
N 41° 05.642  
W 117° 41.427  
Nad 83/WGS 84

41.094, 132° 0N NA 27 D.D.  
117.689, 488° W

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
From 11 Inches To 120 Feet  
Inches Feet  
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Sched 40	20	120
6 3/8	Steel	188	0	20

Perforations:  
Type perforation Hand cut  
Size perforation .125 x 3"  
From 100 feet to 120 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 50 feet to 120 feet

9. WATER LEVEL  
Static water level 43' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Clear

Date started 5-14-10, 2010  
Date completed 5-21, 2010

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	None	6

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Alternative Drilling Contractor  
Address 197 Western Hills #7 Contractor  
Spring Creek NV  
Nevada contractor's license number issued by the State Contractor's Board 73955  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730  
Signed Herold Mont  
By driller performing actual drilling on site or contractor  
Date 6-9-2010