

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 111473  
Permit No. 071  
Basin 071

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65572

1. OWNER Gerald & Sharon Conklin ADDRESS AT WELL LOCATION West Lynx Dr @ Grass Valley Rd  
MAILING ADDRESS 699 Grass Valley Rd Winnemucca, Nv 89445  
Winnemucca, Nv 89445 Subdivision Name: 0 County: Humboldt

2. LOCATION SE 1/4 SW 1/4 Sec 12 T 35N N/S R 37E E Latitude 40 55.039n UTM E NAD 27  
PERMIT/WAIVER No. 0 Parcel No. 013-493-05 Longitude 117 046.19w N

3. WORKED PERFORMED  Deepen  Replace  Other  Recondition  
4. PROPOSED USE  Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor  Air  Other  RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	7	7
brown clay. Silt and sand		7	130	123
Sand gravel & clay		130	160	30
sand		160		
Black sand, small gravel & clay				
brown clay				
gravel				

211 AUG 0 10:42  
STATE OF NEVADA

9. WELL CONSTRUCTION  
Depth Drilled 160 Feet Depth Cased 160  
HOLE DIAMETER (BIT SIZE)  
From 0 To 160  
10 7/8 Inches 0 Feet 160 Feet  
         Inches          Feet          Feet  
         Inches          Feet          Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	STEEL	.188	0	20
6.900	PVC	sdr21=.450 in	20	160

Perforations:  
Type of perforation 6 inch pvc mill horizontal slot screen  
Size of perforation 1/32  
From 120 feet to 160 feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet  
From          feet to          feet

Annular Seal:  Yes  No  
Neat Cement          to          Pumped  Poured   
Cement Grout 4 to 100 Pumped  Poured   
Concrete Grout          to          Pumped  Poured   
≥30% Bentonite Grout          to          Pumped  Poured   
Gravel Pack:  Yes  No 101 to 160 Pumped  Poured   
Type:          3/8 minus  
Bentonite Chips:  Yes  No 100 to 101 Pumped  Poured   
Type:          3/8 baroid

Date started: 7/15/2010  
Date completed: 7/18/2010  
160.00

7. Water Level  
Static water level: 62 feet below land surface  
Artesian Flow:          G.P.M.          P.S.I.  
Water Temperature: COLD °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift	x
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	2
AIR		15	3	

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name High Desert Drilling LLC  
Contractor 4225 E Mary Way  
Winnemucca Nevada 89445  
Nevada contractor's license number 62237  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2140 & 2364  
Signed [Signature]  
By driller performing actual drilling or site contractor  
Date 8/2/2010

MHT-F