STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111520
Permit No. 53919
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34677

1. OWNER LAS VEGAS VALLEY WATER DIST. W073 - DSB
MAILING ADDRESS 1001 S. VALLEY VIEW LAS VEGAS, NV.
ADDRESS AT WELL LOCATION 6611 SMOKE RANCH LAS VEGAS, NV
Subdivision Name: County: Clark

2. LOCATION NW ¼ NW ¼ Sec 23 T 20S N/S R 60 E
PERMIT/WAIVER No. 53919 (Issued by Water Resources) 13823110016 Parcel No.
Latitude 36.203025 Longitude 115.239925
UTM E 658231.625 N 4007905.75 ☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☒ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BAIL TO 1034 FT				
CEMENT BACK TO 1014FT				
W / NEAT CEMENT		1014	1034	20
BRUSH & SWAB		450	770	320
BRUSH & SWAB		850	900	50

Orig log # 34517
Existing log # 68628 (reconditioning)

DCNR/DWR
RECEIVED
JUN 24 2010
LAS VEGAS OFFICE

Date started: 26-Apr, 20 10
Date completed: 24-Jun, 20 10

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased 1034 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
20 "				

Perforations:
Type of perforation S.S. SCREEN
Size of perforation
From 450 feet to 770 feet
From 854 feet to 1014 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 244 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LAS VEGAS VALLEY WATER DIST. (Contractor)
Address 1001 S. VALLEY VIEW LV. NV. (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* N/A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1594
Signed (By driller performing actual drilling on site or contractor)
Date 6/25/2010

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY