WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534,340

OFFICE USE ONLY
Log No. 111671
Permit No. 77581
Basin 103

NOTICE OF INTENT NO. 65564

1. OWNER Frank Pedlar
MAILING ADDRESS PO Box 494 Silver City NV 89428
ADDRESS AT WELL LOCATION Silver City NO ADDRESS

2. LOCATION SE ¼ SE ¼ Sec. 17 T. 16 N/S R. 21 E. — , Lyon County
PERMIT NO. 77581 (Issued by Water Resources) SEC. 08 | 08-061-06 (Parcel No.) Subdivision Name

3. WORK PERFORMED 8/22/11
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Const.
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Dirt Rock & Clay		0	22	22
Green rock		22	54	32
Assorted Colored Frac. Rock		54	75	21
Small Colored rock &		75	—	~~55~~
Soft Green clay	X	—	130	55 ~~15~~
Assorted Colored rock	X	130	145	15
Medium to Large Colored	X	145	—	—
Rock with some clay	X	—	257	112
Hard rock and Fractures		257	275	18
Assorted colored Sand & Fractures	X	275	315	43
Black Fractures		315	340	22
Assorted Fractures and	X	340	~~377~~	—
Small Sand colors	X	—	377	37

NAD-27GPS
39.261717°N
119.641800°W

Date started 6-16, 2010
Date completed 6-19, 2010

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
80+		3 hrs

8. WELL CONSTRUCTION
Depth Drilled 377 Feet Depth Cased 377 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	102 Feet
9 7/8 Inches		102 Feet	377 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	377

Perforations:
Type perforation Buzz Saw
Size perforation 3/16 + 6 inch
From 136 feet to 252 feet
From 273 feet to 315 feet
From 336 feet to 377 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 102
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 102 feet to 377 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow NO G.P.M. 80+ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Well Drilling (Contractor)
Address PO Box 1255 (Contractor) CC NV 89702
Nevada contractor's license number issued by the State Contractor's Board 46497
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2137
Signed (By driller performing actual drilling on site or contractor)
Date 7-10-10

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627