STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111674
Permit No.
Basin 101

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 60744 (i)

1. OWNER Dennis McCrosky
MAILING ADDRESS 113 Heartpine
ADDRESS AT WELL LOCATION 1501 Harmon Road
Fallon, NV
Subdivision Name: County: Churchill

2. LOCATION SE ¼ NE ¼ Sec 23 T 19N N/S R 29 E
PERMIT/WAIVER No. 00755127 Issued by Water Resources
Parcel No.
Latitude N39°29'963 Longitude W118°41'330
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Dense Clay		0	9	9
Brown Sand	X?	9	32	23
Black mushy clay	X?	32	54	22
Green Dense Clay		54	70	16
Brown Dense Clay		70	87	17
Green Dense Clay		87	108	21
Black mushy clay	X?	108	124	16
Green Dense Clay		124	147	23
Black mushy clay	X?	147	172	25
Green Dense Clay		172	225	53
39.499465°N NAD 27 D.D.				
118.687851°W -GPS-				
NOTE: It is my opinion that the only water that MAY be usable in this borehole is the strata in the BROWN SAND. Everything else was really dense and smelly. The black mushy areas were oily mush that the water may not separate from.				
* The decision was made to plug this bore hole.				

Date started: 19-Jan, 20 10
Date completed: 22-Jan, 20 10

9. WELL CONSTRUCTION
Depth Drilled 225 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	225	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blain Drilling (Contractor)
Address PO Box 1255 CC NV 89702 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed (By driller performing actual drilling on site or contractor)
Date 2/9/2010

(Rev. 05-08)

USE ADDITIONAL SHEETS IF NECESSARY

MNH-(F)