

STATE OF NEVADA DIVISION OF WATER RESOURCES WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 111683
 Permit No. _____
 Basin 184

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.840

NOTICE OF INTENT NO. 35315

1. OWNER BLM
MAILING ADDRESS HC-33 Box 33500
Ely, NV 89301

ADDRESS AT WELL LOCATION South Millick
SPR 70182

2. LOCATION SE ¼ SW ¼ Sec 25 T 17N N/S R 87 E
PERMIT/WAIVER No. MO 28 49 010-380-01

Subdivision Name: _____
County: White Pine
Latitude 725148 UTM E NAD 27
Longitude 4353606 N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

Material	Water Strata	From	To	Thickness
Brown clay		0	7	7
Light brown clay with sand and gravel		7	15	8
Light brown clay with sand and gravel		15	20	5
Light brown clay with coarse gravel		25	31	6

WELL CONSTRUCTION	
Depth Drilled	31 Feet
Depth Cased	31 Feet
HOLE DIAMETER (BIT SIZE)	
From	To
8 inches	0 feet
inches	31 feet
inches	feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.250	.64	.125	0	31

Perforations:	
Type of perforation	Factory Slotted
Size of perforation	020
From	16 feet to 31 feet
From	feet to feet
From	feet to feet
From	feet to feet
From	feet to feet

Annular Seal:	
<input checked="" type="checkbox"/> Neat Cement	0 to 11 <input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Paired
<input type="checkbox"/> Cement Grout	to <input type="checkbox"/> Pumped <input type="checkbox"/> Paired
<input type="checkbox"/> Concrete Grout	to <input type="checkbox"/> Pumped <input type="checkbox"/> Paired
<input type="checkbox"/> ≥30% Bentonite Grout	to <input type="checkbox"/> Pumped <input type="checkbox"/> Paired
Gravel Pack: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	14 to 31 <input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Paired
Type:	#3 Silica
Bentonite Chips: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	11 to 14 <input type="checkbox"/> Pumped <input checked="" type="checkbox"/> Paired
Type:	3/8 Chips

Date started: 4-May
Date completed: 4-May

7. Water Level
Static water level: 7 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I.
Water Temperature: N/A °F
Quality: Good

WELL TEST DATA			
TEST METHOD:	<input checked="" type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Bailer	.5	1	5

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WDC Exploration & Wells
 Address 570 Corinthian Way
North Las Vegas, NV 89030
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2371
 Signed [Signature]
 Date 6/3/2010

JUN 04 2010 USE ADDITIONAL SHEETS IF NECESSARY

COPY LAS VEGAS OFFICE

**DCNR/DWR
RECEIVED**