

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50789

1. OWNER LUMOS ADDRESS AT WELL LOCATION Fuji Park Carson City, NV  
 MAILING ADDRESS 5401 Longley Ln ST#5  
Reno, NV 89511  
 2. LOCATION SE 1/4 SE 1/4 Sec 31 T. 15 N. R. 20 E Carson County  
 PERMIT NO. M101335 | 09-203-03 | Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG mw 3

Material	Water Strata	From	To	Thick-ness
<u>sandy gravel</u>		<u>12</u>	<u>20</u>	
<b>Well excavated by F. &amp; P. Construction. 8/17/2010</b>				
<u>NAD-27 G.P.S.</u>				
<u>39.114785° N</u>				
<u>119.772958° W</u>				
<b>DCNR/DWR RECEIVED</b>				
<b>DEC 02 2004</b>				
<b>LAS VEGAS OFFICE</b>				

8. WELL CONSTRUCTION  
 Depth Drilled 20 Feet Depth Cased 20 Feet  
 HOLE DIAMETER (BIT SIZE)  
8 Inches From 0 Feet To 20 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>20</u>

Perforations:  
 Type perforation Factory  
 Size perforation 3/20  
 From 10 feet to 20 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 8  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No From 0 feet to 20 feet

9. WATER LEVEL  
 Static water level 12 feet below land surface  
 Artesian flow N/A G.P.M. N/A P.S.I.  
 Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Andresen Exploration Drilling  
 Address 1135 Belford Rd. Reno, NV 89509  
 Nevada contractor's license number 34525  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1028  
 Division of Water Resources, the on-site driller  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_

Date started 8/24 2009  
 Date completed 8/24 2009

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>N/A</u>	<u>N/A</u>	