WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

# STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 111824
Permit No. 67662
Basin 162

NOTICE OF INTENT NO. 35430

1. OWNER MID VALLEY ENTERPRISES LLC
MAILING ADDRESS 10551 S HOMESTEAD RD
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 10551 S HOMESTEAD RD

2. LOCATION NW 1/4 NW 1/4 Sec. 6 T 22 N/S R 54 E NYE County
PERMIT NO. 67662 (Issued by Water Resources) | 45-471-08 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---|---|---|---|---|
| N36°04'12.2" | | | | |
| W115°57'23.3" | | | | |
| PERF WELL FROM 270' TO 50' WITH MILLS KNIFE. | | | | |
| PUMP BENTONITE GROUT FROM BOTTOM TO 80' WITH | | | | |
| TRIMIE PIPE. | | | | |
| FROM 80' TO SURFACE PUMP NEAT CEMENT_USED 95 CUBIC | | | | |
| FT BENTONITE GROUT_USED 30 CUBIC FT NEAT CEMENT | | | | |

DCNR/DWR
RECEIVED
AUG 27 2010
LAS VEGAS OFFICE

Date started 8/25/2010 , 19__
Date completed 8/25/2010 , 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 274 Feet Depth Cased 274 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| EXISTING | Inches | 0 | Feet | 274 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8" | 16.94 | .188 | 0 | 274 |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal EXISTING
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address 1220 E MANSE RD (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed (By driller performing actual drilling on-site or contractor)
Date 8/25/2010

USE ADDITIONAL SHEETS IF NECESSARY