

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111831
Permit No. _____
Basin 117

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35206

1. OWNER RICHARD TREMAINE ADDRESS AT WELL LOCATION PALMETTO LANE
MAILING ADDRESS P.O. Box 248 DYER NV. 89010 WESTSIDE LOT 30
Subdivision Name: WHITE WOLF MEADOWS County: ESMERALDA

2. LOCATION NW 1/4 NE 1/4 Sec 8 T 4 N R 36 E Latitude 37° 36.747 UTM E NAD 27
PERMIT/WAIVER No. 007-557-02 Longitude 118° 00.214 N NAD 83/WGS 84

Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other _____

4. PROPOSED USE
 Domestic Irrigation Test Stock
 Municipal/Industrial Monitor

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>EXISTING 6" WELL</u>		<u>0</u>	<u>122</u>	<u>122</u>
<u>CLEAN OUT FILL</u>		<u>122</u>	<u>160</u>	<u>38</u>
<u>CLAY + GRAVEL</u>		<u>160</u>	<u>170</u>	<u>10</u>
<u>SAND + GRAVEL</u>	<u>W.B.</u>	<u>170</u>	<u>185</u>	<u>15</u>
<u>CLAY + SAND</u>		<u>185</u>	<u>220</u>	<u>35</u>
<u>SAND + GRAVEL</u>	<u>W.D.</u>	<u>220</u>	<u>300</u>	<u>80</u>

7. Water Level
Static water level: 147 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: COOL °F
Quality: _____

8. WELL TEST DATA
TEST METHOD: Bailer Pump Air Lift
G.P.M. Draw Down (Feet Below Static) Time (Hours)

9. WELL CONSTRUCTION

Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

From	To	Feet	Feet
<u>5 7/8</u> Inches	<u>160</u> Feet	<u>300</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2"</u>	<u>2.36</u>	<u>PVC 248</u>	<u>0</u>	<u>300</u>

Perforations:

Type of perforation FACTORY SCREEN
Size of perforation .032 x 14 ROW

From 300 feet to 240 feet
From _____ feet to _____ feet

Annular Seal: Yes No EXISTING

Neat Cement to _____ Pumped Poured
 Cement Grout to _____ Pumped Poured
 Concrete Grout to _____ Pumped Poured
 ≥30% Bentonite Grout to _____ Pumped Poured

Gravel Pack: Yes No 300 to 100 Pumped Poured
Type: #8 COLORADO SILICA SAND

Bentonite Chips: Yes No _____ to _____ Pumped Poured
Type: _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name BUDGET DRINKING CO. Contractor
Address P.O. Box 3505 PATRUMP NV. 89041 Contractor
Nevada contractor's license number _____
issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573

Signed [Signature]
By driller performing actual drilling on-site or contractor
Date 7-13-2010