

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. **111848**
Permit No. _____
Basin **212**

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **35382**

1. OWNER **Tronox LLC c/o Tax Department** ADDRESS AT WELL LOCATION **8000 E. Lake Mead Parkway**
MAILING ADDRESS **P.O. Box 268859** **M-148A** **Henderson, NV 89015**
Oklahoma City, OK 73126 Subdivision Name: _____ County: **Clark**

2. LOCATION SW ¼ **SE** ¼ Sec 12 T 22 N 62 E Latitude **36.0240.42N** UTM E NAD 27
PERMIT/WAIVER No. **178-12-801-001** Longitude **114.5954.89W** N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Other Sonic

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
Sand and Gravel Silty		0	11	11
Sand Silty		11	22	11
Sand Gravelly		22	38	16
Sand	WL	38	45	7
Silt		45	50	5


9. WELL CONSTRUCTION				
Depth Drilled	50	Feet	Depth Cased	50
HOLE DIAMETER (BIT SIZE)				
	From	To		
6	Inches 0	Feet 50		Feet
	Inches	Feet		Feet
	Inches	Feet		Feet
CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.25	.64	.125	0	50

Perforations:
Type of perforation **Factory Slotted**
Size of perforation **.010**
From **40** feet to **50** feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
Annular Seal: Yes No
 Neat Cement **0** to **35** Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured
Gravel Pack: Yes No **38** to **50** Pumped Poured
Type: **10/20 Silica**
Bentonite Chips: Yes No **35** to **38** Pumped Poured
Type: **3/8 Chips**

Date started: **2-Jun**, 20 **10**
Date completed: **2-Jun**, 20 **10**

7. **Water Level**
Static water level: **43.4** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I.
Water Temperature: **N/A** °F
Quality: **Good**

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
NA			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **WDC Exploration & Wells**
Contractor
Address **570 Corinthian Way, N. Las Vegas, NV 89030**
Contractor
Nevada contractor's license number issued by the State Contractor's Board **0012852**
Nevada driller's license number issued by the Division of Water Resources, the on-site driller **M-2371**
Signed 
By driller performing actual drilling on site or contractor
Date **6/17/2010**

LAS VEGAS OFFICE