

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 111882  
Permit No. -  
Basin 083

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65932

1. OWNER Waste Management ADDRESS AT WELL LOCATION Lockwood Regional Landfill  
MAILING ADDRESS 2461 Canyon way Sparks NV 89734 Subdivision Name: \_\_\_\_\_ County: Storey  
2. LOCATION NW 1/4 SW 23 T 19 S R 21 E Latitude N 39.49803° UTM E  NAD 27  
PERMIT/WAIVER No. SW 24861 804-131-04 Longitude W 119.60867° N  NAD 83/WGS 84  
Issued by Water Resources Parcel No. \_\_\_\_\_

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  Stock  
 Municipal/Industrial  Monitor

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silt Stone</u>	<u>NO</u>	<u>0</u>	<u>20</u>	<u>20</u>
<u>m-s</u>				
<u>NAD-27 bps</u>				
<u>39.49803° N</u>				
<u>119.60867° W</u>				

9. WELL CONSTRUCTION

Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
<u>8</u>	<u>0</u>	<u>20</u>	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>sch 40</u>	<u>0</u>	<u>10</u>

Perforations:

Type of perforation Factory Slot  
Size of perforation .020

From	feet to	feet
<u>10</u>	<u>20</u>	

Annular Seal:  Yes  No

Neat Cement 0 to 4  Pumped  Poured  
 Cement Grout to  Pumped  Poured  
 Concrete Grout to  Pumped  Poured  
 ≥30% Bentonite Grout to  Pumped  Poured

Gravel Pack:  Yes  No 8 to 20  Pumped  Poured  
Type: #8 silica sand

Bentonite Chips:  Yes  No 6 to 8  Pumped  Poured  
Type: 3/8 Bentonite chips

Date started: August 25th, 20 10  
Date completed: August 25th, 20 10

7. Water Level

Static water level: N/A feet below land surface  
Artesian Flow: no G.P.M. P.S.I.  
Water Temperature: N/A °F  
Quality: \_\_\_\_\_

8. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HAZ-Tech Drilling Inc Contractor  
Address P.O. Box 940 Contractor  
Meridian Id 83680  
Nevada contractor's license number 0038018  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2412-JM-LTD

Signed [Signature]  
By driller performing actual drilling on-site or contractor  
Date 8/31/10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY