STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111896
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 35351

1. OWNER 7-11 Inc % AV Tax Dept # 29646
MAILING ADDRESS P.O. Box 711
Dallas, TX 75221-0711

ADDRESS AT WELL LOCATION 4325 W. Sahara Ave
AS-7 Las Vegas, NV
Subdivision Name: County: Clark

2. LOCATION NW ¼ NE ¼ Sec 7 T 21S N/S R 61 E
PERMIT/WAIVER No. 162-07-501-001
Issued by Water Resources Parcel No.

Latitude 36.08643 ?
Longitude 115.11966
UTM E N
[x] NAD 27
[ ] NAD 83/WGS 84

3. WORKED PERFORMED
[x] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [x] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [x] Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	3	3
Silty Sand		3	4	1
Sandy Silt		4	7	3
Caliche		7	10	3
Sand		10	15	5
Clayey Sand		15	21	6
Sand		21	30	9
Caliche		30	31	1

DCNR/DWR RECEIVED JUL 12 2010 LAS VEGAS OFFICE

Date started: 22-Jun , 20 10
Date completed: 22-Jun , 20 10

9. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 31 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	31	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.374		Sch 40	0	31

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 29 feet to 31 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [x] Yes [ ] No

[ ] Neat Cement	to		[ ] Pumped	[ ] Poured
[x] Cement Grout	1 to 25		[x] Pumped	[ ] Poured
[ ] Concrete Grout	to		[ ] Pumped	[ ] Poured
[ ] ≥30% Bentonite Grout	to		[ ] Pumped	[ ] Poured

Gravel Pack: [x] Yes [ ] No 27 to 31 [ ] Pumped [x] Poured
Type: #3 Monterey Sand
Bentonite Chips: [x] Yes [ ] No 25 to 27 [ ] Pumped [x] Poured
Type: 1/2" Bentonite Pellets

7. Water Level
Static water level: 23.1 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: [x] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		.5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WDC Exploration & Wells
Contractor
Address 570 Corinthian Way
Contractor
N. Las Vegas, NV 89030
Nevada contractor's license number issued by the *State Contractor's Board* 0012852
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* M-2381
Signed
By driller performing actual drilling on site or contractor
Date 7-12-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY