STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111912
Permit No.
Basin 228

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65471

1. OWNER U.S.A
MAILING ADDRESS Washington D.C.
ADDRESS AT WELL LOCATION Gold Butte
Subdivision Name: County: Clark

2. LOCATION SW¼ NE¼ Sec 15 T 19 N OR 70 E
PERMIT/WAIVER No. 114-00-001-002
Issued by Water Resources Parcel No.
Latitude 36° 17.126
Longitude 114° 09.504
UTM E N
☐ NAD 27 ☑ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Other PLUG

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Neat Cement		0	34	34
18 - 94 lb Bags				
of cement and				
water pumped				
through 2" pipe				
from bottom up				

DCNR/DWR RECEIVED JUL 26 2010 LAS VEGAS OFFICE

Date started: June 22, 20 10
Date completed: June 22, 20 10

9. WELL CONSTRUCTION
Depth Drilled 34 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0	Feet	34	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8		.250	-1	30

Perforations:
Type of perforation Mills Knife
Size of perforation 1/4" x 3" 4 cuts per foot
From 0 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☑ Neat Cement 0 to 34 ☑ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 8 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Anzalone Pumps Inc. (Contractor)
Address 3632 N. 250 E. (Contractor)
Enoch, UT 84721
Nevada contractor's license number issued by the State Contractor's Board 0073603
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2406
Signed (By driller performing actual drilling on-site or contractor)
Date July 9 210

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY