STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 111972
Permit No. -
Basin 104

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44336

1. OWNER NDEP
MAILING ADDRESS 901 S. Stewart St. Ste. H001
Carson City, NV. 89701

ADDRESS AT WELL LOCATION Eagle Bas 2152 N Carson St
Carson City NV 89701
Subdivision Name: County: Carson City

2. LOCATION SW ¼ NW ¼ Sec 3 T 15 N/S R 20 E
PERMIT/WAIVER No. I-000030 Issued by Water Resources
Parcel No. ROW

Latitude N39.18058°
Longitude W119.76723°
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC ☐ Air ☒ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel	NO	0	5	5
Sand Gravel Clay	Yes	5	10	5
Sand Clay	Yes	10	25	15
MW-14				
NAD-27 GPS				
39.180670°N				
119.766215°W				
redrilled/replaced by 120018				

Date started: August 10th, 20 10
Date completed: August 11th, 20 10

7. Water Level
Static water level: 10 feet below land surface
Artesian Flow: NO G.P.M. P.S.I.
Water Temperature: <45 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	0	5

Perforations:
Type of perforation Factory Slot
Size of perforation .020
From 5 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 2 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4 to 25 ☐ Pumped ☒ Poured
Type: #4/20 silica sand
Bentonite Chips: ☒ Yes ☐ No 2 to 4 ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Chips

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HAZ-Tech Drilling Inc (Contractor)
Address P.O. Box 940 (Contractor)
meridian, Id 83680
Nevada contractor's license number issued by the State Contractor's Board 0038098
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2472-M-LTD
Signed (By driller performing actual drilling on-site or contractor)
Date 8/31/10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627