STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Log No. 112030
Permit No. —
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 64940

1. OWNER CITY OF ELKO
MAILING ADDRESS 1751 COLLEGE AVE. ELKO NV, 89801

ADDRESS AT WELL LOCATION WELL ID # L10
CITY OF ELKO RECLAMATION FACILITY
Subdivision Name: County: Elko

2. LOCATION NW ¼ SW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. NEV-20014 (Issued by Water Resources) Parcel No.

Latitude 40* 47.222 N
Longitude 115* 47.650 W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE CLAY		0'	5'	5'
GREEN CLAY		5'	40'	35'
RED CLAY		40'	75'	35'
GRAVEL		75'	170'	95'

NAD-27 GPS
40.787112 °N
115.793265 °W
L-10

Date started: 11-Sep, 20 10
Date completed: 11-Sep, 20 10

9. WELL CONSTRUCTION
Depth Drilled 170' Feet Depth Cased 165' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8"	Inches	0'	Feet	170'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5"		SCH. 40	+1'	165'

Perforations:
Type of perforation SCREEN
Size of perforation 0.020"

From	115'	feet to	125'	feet
From	135'	feet to	145'	feet
From	155'	feet to	165'	feet
From		feet to		feet
From		feet to		feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0' to 10'	☒ Pumped	☐ Poured
☐ Cement Grout	10' to 111'	☒ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☒ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 111' to 170' ☐ Pumped ☒ Poured
Type: 8 X 16
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 118' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT	5		30 MIN

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Hydro Resources-West, Inc. (Contractor)
Address 4975 W. Winnemucca Blvd. (Contractor)
Winnemucca NV, 89445
Nevada contractor's license number issued by the State Contractor's Board 56797
Nevada driller's license number issued by the Division of Water Resources, the on-site driller # 1713
Signed (By driller performing actual drilling on site or contractor)
Date 4-14-10

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY