STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 117049
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 62967 (1)

1. OWNER Tony Brill
MAILING ADDRESS 435 Lyndon Unit #14
Elko NV 89801

ADDRESS AT WELL LOCATION 18 Miles out Jungo Rd from WMCA
Subdivision Name: —
County: Humboldt

2. LOCATION SE ¼ SW ¼ Sec 33 T 36 N/S R 35 E
PERMIT/WAIVER No. ____ Issued by Water Resources
Parcel No.

Latitude
Longitude

UTM E 411464 ☒ NAD 27
N 4533040 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Rock + Sand		3	20	17
Rock + Gravel		20	40	20
Rock		40	60	20
Rock + Gravel		60	100	40
Sand Rock + Clay		100	120	20
Rocky Clay		120	140	20
Gravel + Rock		140	160	20
Rocky Clay		160	180	20
Rock + Gravel		180	200	20
Sand Gravel + Rock		200	220	20
Rock + Gravel		220	240	20
Rock Gravel + Sand		240	260	20

40.945609 N NAD27
118.051827 W

Date started: 8-26, 20 10
Date completed: 9-6, 20 10

7. Water Level
Static water level: 180 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	30	Unk	3 Hrs.

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	260

Perforations:
Type of perforation Torch Cut
Size of perforation 3/16 x 6

From	feet to	feet
200	260	

Annular Seal: ☐ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	5	to 60	☐ Pumped	☒ Poured
☐ ≥80% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 180 to 260 ☐ Pumped ☒ Poured
Type: 3/8 —
Bentonite Chips: ☒ Yes ☐ No 60 to 180 ☐ Pumped ☒ Poured
Type: 3/8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources the *on-site driller* 1807
Signed Joe Boggio (By driller performing actual drilling on site or contractor) Joe Boggio
Date

(Rev 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

MMH-(F)