STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112054
Permit No.
Basin 129

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65979 (i)

1. OWNER Victoria Clarke
MAILING ADDRESS 1205 Unionville Rd

ADDRESS AT WELL LOCATION 1205 Unionville Rd
Unionville NV 89418
Subdivision Name: County: Pershing

2. LOCATION NW ¼ SE ¼ Sec30T30N/ R35E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 012-080-25 (Parcel. No.)

Latitude N40°26.418 UTM E ☐ NAD 27
Longitude W118°05.232 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Course gravel rock	X	340	360	20
Boulder		360	380	20
Sand brown w/gravel	X	380	390	10
Boulders		390	410	20
Course gravel		410	415	5
sand & Gravel	X	415	425	10
Boulders		425	430	5

40.440392°N NAD27
118.086228°W

*original log being deepened - unknown

Date started: September 29, 2010
Date completed: October 4, 2010

7. Water Level
Static water level: 334 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10-12		4.5

9. WELL CONSTRUCTION
Depth Drilled 430 Feet Depth Cased 430 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	340 Feet	430 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	.188	230	430

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32 X 4
From 390 feet to 430 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☐ Yes ☐ No Natural to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources/the on-site driller 2083
Signed Fred Anderson Drilling Inc
By driller performing actual drilling on site or contractor
Date October 6, 2010

(Rev 05-06) USE ADDITIONAL SHEETS IF NECESSARY

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com

MMF (F)