

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 62639

1. OWNER Victoria Resources (US) INC ADDRESS AT WELL LOCATION 1 OF 2 Wells  
 MAILING ADDRESS 240 South Rock Blvd Suite, 117 Big Springs NV, Reno, NV 89502  
 2. LOCATION NEDE DESG 1/4 Sec A 02 T 42 North Fork Rd. Basin 044  
 PERMIT NO. M/O 1638A Issued by Water Resources Forest Service GPS. Nad # 83 Elko, CO. County Elko  
 Subdiv 044

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
B5M.W-#9				
Dump Fill		0	28	28'
Black to Gray Blk Rock 1 to 1 1/2 Gpm.	✓	28	118'	90'
Gray to Black Bed Rock with Fractures.	✓	118'	363'	245'
Nad 83	N	41°	33,630	
<del>W 115° 58, 099</del>	W	115°	58, 099	
<del>W 115° 58, 099</del>				

41.560594°N  
 115.967397°W  
 NAD 27 (TS)

8. WELL CONSTRUCTION  
 Depth Drilled 363' Feet Depth Cased 355' Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 3/4" Inches	0 Feet 38 1/2" Feet
6" Inches	38-6 Feet 36 3/4" Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	131kg	.188	+18"	to 39'
2" ID PVC	Sch. 80		+18"	355'

Perforations:  
 Type perforation 100 slot machined  
 Size perforation 100 slot  
 From 298-6 feet to 348-6 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 348-6 to \_\_\_\_\_ feet to 355 Blank feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 120'  Neat Cement  
 Placement Method:  Pumped 38" Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No BENTONITE GROUT  
 From 120' feet to 355-363' feet

9. WATER LEVEL  
 Static water level 54-3" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Leach Drilling INC  
 Address PO Box 599  
Silver Springs, NV 89429  
 Nevada contractor's license number 31841  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1740  
 Signed Nathan L. Leach  
 By driller performing actual drilling on site or contractor  
 Date Oct. 15/2010

Date started Sept 1, 2010  
 Date completed Sept 26, 2010

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>56 gpm</u>	<u>301'</u>	<u>8 hrs. at end.</u>