

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 112095  
Permit No. 76478  
Basin 064

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **65577**

1. OWNER Shawn Goemmer ADDRESS AT WELL LOCATION 2650 Allen Rd  
MAILING ADDRESS PO Box 517 Battle Mtn, Nv 89820  
Subdivision Name: 0 County: Lander  
2. LOCATION NE 1/4 NW 1/4 Sec 10 T32N N/S R R44E E Latitude 40 40.156n UTM E NAD 27  
PERMIT/WAIVER No. 76478 Parcel No. 010-270-03 Longitude 117 00.399w N X  
Issued by Water Resources SEE WELL LOG # 4008

3. WORKED PERFORMED  
New Well  Replace  Recondition  Other   
4. PROPOSED USE  
Domestic   Irrigation  Test   
Municipal/Industrial  Monitor  Stock   
5. WELL TYPE  
Cable  RVC   
Air  Other

6. LITHOLOGIC LOG

| Material             | Water Strata | From | To  | Thick-ness |
|----------------------|--------------|------|-----|------------|
| See well log 4008    |              | 0    | 120 | 120        |
| Sand                 | x            | 120  | 222 | 102        |
| Clay & gravel & sand | x            | 222  | 231 | 9          |
|                      |              | 231  |     |            |

9. WELL CONSTRUCTION  
Depth Drilled 230 Feet Depth Cased 230  
HOLE DIAMETER (BIT SIZE)  
9 7/8 Inches From 120 Feet To 230 Feet  
Inches Feet Feet Feet  
Inches Feet Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/FL (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|--------------------|-------------------------|-------------|-----------|
| 8.625              | STEEL              | .188                    | 0           | 230       |

Perforations:  
Type of perforation mill saw cut  
Size of perforation 3/32  
From 110 feet to 230 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  
Neat Cement \_\_\_\_\_ to \_\_\_\_\_ Pumped Poured  
Cement Grout \_\_\_\_\_ to \_\_\_\_\_ Pumped Poured  
Concrete Grout \_\_\_\_\_ to \_\_\_\_\_ Pumped Poured  
≥30% Bentonite Grout 0 to 54 Pumped  Poured  
Gravel Pack: Yes  No \_\_\_\_\_ to \_\_\_\_\_ Pumped Poured  
Type: \_\_\_\_\_  
Bentonite Chips: Yes  No \_\_\_\_\_ to \_\_\_\_\_ Pumped Poured  
Type: \_\_\_\_\_

Date started: 10/15/2010  
Date completed: 10/23/2010

7. Water Level  
Static water level: 88 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COLD °F  
Quality: good

8. WELL TEST DATA

| TEST METHOD: | Bailer |                               | Pump | Air Lift | Time (Hours) |
|--------------|--------|-------------------------------|------|----------|--------------|
|              | G.P.M. | Draw Down (Feet Below Static) |      |          |              |
| AIR          | 50     | 50                            |      |          | 4            |

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name High Desert Drilling LLC  
Contractor  
Address 4225 E Mary Way  
Contractor  
Winnemucca Nevada 89445  
Nevada contractor's license number issued by the State Contractor's Board 62237  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2364  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 10-24-10

USE ADDITIONAL SHEETS IF NECESSARY  
40.669356°N  
117.0057130W  
NAD 27 TO