

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 112096
Permit No. _____
Basin 477

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 65856

1. OWNER Barride Gold ADDRESS AT WELL LOCATION Bald note mine
MAILING ADDRESS Box 2706 Elko NV 89803 Subdivision Name: _____ County: WHITE PINE

2. LOCATION NE 1/4 NE 1/4 Sec 22 T 24 N R 560 Latitude 39.947512°N UTM E 615642 NAD 27
PERMIT/WAIVER No. PZ-1017 MO-1627 Longitude 115.645416°W N 4422801 NAD 83/WGS 84
Parcel No. N30 27 (A)

3. WORKED PERFORMED New Well Replace Recondition Deepen Other
4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
5. WELL TYPE Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium</u>	<u>0</u>	<u>0</u>	<u>260</u>	<u>260</u>
<u>Black clay</u>	<u>0</u>	<u>260</u>	<u>360</u>	<u>100</u>
<u>Mixture of clays</u>	<u>270</u>	<u>660</u>		
<u>1st water contact at 560' 279m. maintained 27 to 26 gm all the way to 660'</u>	<u>270</u>	<u>260</u>	<u>660</u>	<u>400</u>

9. WELL CONSTRUCTION
Depth Drilled 660 Feet Depth Cased 660 Feet
HOLE DIAMETER (BIT SIZE)
10' From 0 To 660'
Inches _____ Feet _____
Inches _____ Feet _____
Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>		<u>Sec 80</u>	<u>560'</u>	<u>660'</u>

Perforations:
Type of perforation Mill slot
Size of perforation 1/2"
From 560 feet to 660 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 0 to 50' Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 538 to 660 Pumped Poured
Type: 1/4" gravel Tannin'd down
Bentonite Chips: Yes No 538 to 10' Pumped Poured
Type: 3/8 chips poured from top to 10'; 10' to 0' cement Seal

Date started: 9-11-10 20 10
Date completed: 9-14-10 20 10

7. Water Level
Static water level: 476 feet below land surface
Artesian Flow: 0 G.P.M. 0 P.S.I.
Water Temperature: Local °F
Quality: cloudy

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>560'</u>	<u>27</u>	<u>-</u>	<u>5 min / Bucket test</u>
<u>580'</u>	<u>27</u>	<u>-</u>	<u>5 min / Bucket test</u>
<u>600'</u>	<u>26</u>	<u>-</u>	<u>5 min / Bucket test</u>
<u>620'</u>	<u>26</u>	<u>-</u>	<u>5 min / Bucket test</u>
<u>640'</u>	<u>27</u>	<u>-</u>	<u>5 min / Bucket test</u>
<u>660'</u>	<u>25</u>	<u>-</u>	<u>5 min / Bucket test</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boat Langyear NV Contractor
Address Box 2748 Elko NV 89803 Contractor
Nevada contractor's license number _____ issued by the State Contractor's Board 0073086
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2400
Signed BL
By driller performing actual drilling on-site or contractor
Date 9-15-10